

Id	Description	Cooldown	Reheat	Uom Id
1	***not assigned***	○	○	○
2	Turbine, aeroderivative	4.00	1.00	h
3	Turbine, heavy duty	8.00	1.00	h
4	Electric generator	1.50	1.00	h
5	Compressor	3.00	1.00	h
6	Furnace	120.00	60.00	h
7	Heater/boiler	4.00	1.00	h
8	Heat exchanger	2.00	1.00	h
9	High temperature reactor/vessel	8.00	4.00	h
10	Claus thermal reactor/incinerator	48.00	24.00	h
11	Blower	1.00	0.50	h/conn.